

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-0447:117

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** ESL/Sentrol, 12345 SW Levetron Drive, Tualatin, Or 97062  
Contact: Gene Hukkanen (503) 691-7369

**DESIGN:** Model 613U5. 136°F fixed temperature and rate-of-rise. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation and UL label.

**APPROVAL:** Listed as system heat detectors for use with Models 601U and 602U bases (CSFM Listing No. 7300-0447:115) and separately listed compatible control units.



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 2, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy  
Program Manager